

FY2013 Performance

Influent / Effluent			Solids Handling		
	Units	Value		Units	Value
Average Daily Flow	mgd	29.1	Solids to Belt Filter Press (BFP)	%	4.1
Average Raw CBOD	mg/L	160	BFP Cake Solids Contents	%	23.9
Average Final CBOD	mg/L	1.8	BFP Cake to Incinerators	Wet tons	65,450
Average Raw SS	mg/L	162	BFP Cake to Incinerators	Wet tons / hr	7.5
Average Final SS	mg/L	3.1			
Average Raw TN	mg/L	5.3			
Average Final TN	mg/L	5.1			
Average Final TN (May-Oct)	mg/L	5.1			
Average Raw TP (entire year)	mg/L	3.7			
Average Final TP (entire year)	mg/L	0.26			
Average Final TP (Apr-Oct)	mg/L	0.34			

Plant Performance			Other Information		
BOD Removal	%	98.9	Full Time Staff		52
SS Removal	%	98.1	Electrical Energy Used	Million KWH	16.6
TN Removal	%	78	Natural Gas Used	Million CF	70
TP Removal	%	93			