

*FY2015 Performance*

| Influent / Effluent            |       |       | Solids Handling                   |               |        |
|--------------------------------|-------|-------|-----------------------------------|---------------|--------|
|                                | Units | Value |                                   | Units         | Value  |
| Average Daily Flow             | mgd   | 29.4  | Solids to Belt Filter Press (BFP) | %             | 4      |
| Average Raw CBOD               | mg/L  | 176   | BFP Cake Solids Contents          | %             | 23.3   |
| Average Final CBOD             | mg/L  | 2.2   | BFP Cake to Incinerators          | Wet tons      | 67,092 |
| Average Raw SS                 | mg/L  | 167   | BFP Cake to Incinerators          | Wet tons / hr | 7.8    |
| Average Final SS               | mg/L  | 2.6   |                                   |               |        |
| Average Raw TN                 | mg/L  | 27.7  |                                   |               |        |
| Average Final TN               | mg/L  | 5     |                                   |               |        |
| Average Final TN (May-Oct)     | mg/L  | 4.7   |                                   |               |        |
| Average Raw TP (entire year)   | mg/L  | 4     |                                   |               |        |
| Average Final TP (entire year) | mg/L  | 0.24  |                                   |               |        |
| Average Final TP (Apr-Oct)     | mg/L  | 0.21  |                                   |               |        |

| Plant Performance |   |      | Other Information      |             |      |
|-------------------|---|------|------------------------|-------------|------|
| BOD Removal       | % | 98.8 | Full Time Staff        |             | 53   |
| SS Removal        | % | 98.5 | Electrical Energy Used | Million KWH | 16.8 |
| TN Removal        | % | 82   | Natural Gas Used       | Million CF  | 66.3 |
| TP Removal        | % | 93   |                        |             |      |