

FY2015 Performance

Influent / Effluent	Units	Value	Solids Handling	Units	Value
Average Daily Flow	mgd	29.4	Solids to Belt Filter Press (BFP)	%	4
Average Raw CBOD	mg/L	176	BFP Cake Solids Contents	%	23.3
Average Final CBOD	mg/L	2.2	BFP Cake to Incinerators	Wet tons	67,092
Average Raw SS	mg/L	167	BFP Cake to Incinerators	Wet tons / hr	7.8
Average Final SS	mg/L	2.6			
Average Raw TN	mg/L	27.7			
Average Final TN	mg/L	5			
Average Final TN (May-Oct)	mg/L	4.7			
Average Raw TP (entire year)	mg/L	4			
Average Final TP (entire year)	mg/L	0.24			
Average Final TP (Apr-Oct)	mg/L	0.21			

Plant Performance			Other Information		
BOD Removal	%	98.8	Full Time Staff		53
SS Removal	%	98.5	Electrical Energy Used	Million KWH	16.8
TN Removal	%	82	Natural Gas Used	Million CF	66.3
TP Removal	%	93			