

FY2016 Performance

Influent / Effluent			Solids Handling		
	Units	Value		Units	Value
Average Daily Flow	mgd	28.8	Solids to Belt Filter Press (BFP)	%	4.1
Average Raw CBOD	mg/L	185	BFP Cake Solids Contents	%	23.1
Average Final CBOD	mg/L	2.8	BFP Cake to Incinerators	Wet tons	66,730
Average Raw SS	mg/L	178	BFP Cake to Incinerators	Wet tons / hr	7.8
Average Final SS	mg/L	3.4			
Average Raw TN	mg/L	28.9			
Average Final TN	mg/L	5.2			
Average Final TN (May-Oct)	mg/L	4.4			
Average Raw TP (entire year)	mg/L	4.1			
Average Final TP (entire year)	mg/L	0.33			
Average Final TP (Apr-Oct)	mg/L	0.17			

Plant Performance			Other Information		
BOD Removal	%	98.5	Full Time Staff		56
SS Removal	%	98.1	Electrical Energy Used	Million KWH	16.8
TN Removal	%	82.0	Natural Gas Used	Million CF	77.8
TP Removal	%	92			