

FY2017 Performance

Influent / Effluent	Units	Value	Solids Handling	Units	Value
Average Daily Flow	mgd	29.4	Solids to Belt Filter Press (BFP)	%	4.1
Average Raw CBOD	mg/L	168	BFP Cake Solids Contents	%	23.1
Average Final CBOD	mg/L	2.5	BFP Cake to Incinerators	Wet tons	71,127
Average Raw TSS	mg/L	165	BFP Cake to Incinerators	Wet tons / hr	8.2
Average Final TSS	mg/L	2.4			
Average Raw TN	mg/L	27.1			
Average Final TN	mg/L	6.2			
Average Final TN (May-Oct)	mg/L	4.1			
Average Raw TP (entire year)	mg/L	3.5			
Average Final TP (entire year)	mg/L	0.22			
Average Final TP (Apr-Oct)	mg/L	0.2			
Plant Performance			Other Information		
CBOD Removal	%	98.5	Full Time Staff		56
TSS Removal	%	98.5	Electrical Energy Used	Million KWH	16
TN Removal	%	77.1	Natural Gas Used	Million CF	87.2
TP Removal	%	93.7			