

FY2018 Performance

Influent / Effluent			Solids Handling		
	Units	Value		Units	Value
Average Daily Flow	mgd	29.4	Solids to Belt Filter Press (BFP)	%	4.3
Average Raw CBOD	mg/L	154	BFP Cake Solids Contents	%	23.9
Average Final CBOD	mg/L	2.4	BFP Cake to Incinerators	Wet tons	73,737
Average Raw TSS	mg/L	158	BFP Cake to Incinerators	Wet tons / hr	8.6
Average Final TSS	mg/L	2.4			
Average Raw TN	mg/L	27.2			
Average Final TN	mg/L	4.7			
Average Final TN (May-Oct)	mg/L	4.1			
Average Raw TP (entire year)	mg/L	4.1			
Average Final TP (entire year)	mg/L	0.18			
Average Final TP (Apr-Oct)	mg/L	0.2			

Plant Performance			Other Information		
CBOD Removal	%	98.4	Full Time Staff		56
TSS Removal	%	98.5	Electrical Energy Used	Million KWH	16.5
TN Removal	%	82.7	Natural Gas Used	Million CF	86.3
TP Removal	%	95.6			