

FY2019 Performance

Influent / Effluent	Units	Value	Solids Handling	Units	Value
Average Daily Flow	mgd	36.0	Solids to Belt Filter Press (BFP)	%	4.6
Average Raw CBOD	mg/L	137	BFP Cake Solids Contents	%	23.3
Average Final CBOD	mg/L	2.0	BFP Cake to Incinerators	Wet tons	79,961
Average Raw TSS	mg/L	139	BFP Cake to Incinerators	Wet tons / hr	9.1
Average Final TSS	mg/L	2.3			
Average Raw TN	mg/L	23.3			
Average Final TN	mg/L	5.1			
Average Final TN (May-Oct)	mg/L	5.0			
Average Raw TP (entire year)	mg/L	3.03			
Average Final TP (entire year)	mg/L	0.15			
Average Final TP (Apr-Oct)	mg/L	0.17			

Plant Performance			Other Information		
CBOD Removal	%	98.3	Full Time Staff		60
TSS Removal	%	98.1	Electrical Energy Used	Million KWH	16.9
TN Removal	%	78.1	Natural Gas Used	Million CF	96.0
TP Removal	%	95.0			